

AIR-BLOC® 16MR

POLYBITUME® 570-05, 925 BES SEALANT, OR AIR-BLOC® LF (TROWEL UNTIL MEMBRANE EDGE IS FULLY COATED TO PROMOTE WATER SHEDDING)

METAL HEAD FLASHING (TYPICAL)

BLUESKIN® BUTYL FLASH, BLUESKIN® SA, BLUESKIN® SALT, FOILSKIN®, OR AIR-BLOC® LF

HEAD

76 mm MIN

CONFIRM SEALANT COMPATIBILITY WITH ALL SUBSTRATES AND ADJACENT PRODUCTS PRIOR TO INSTALLATION

EXTEND FLASHING 76 mm RECOMMENDED (50 mm MIN) INTO ROUGH OPENING

76 mm MIN

SILL

AIR-BLOC® 16MR

BLUESKIN® BUTYL FLASH, BLUESKIN® SA, BLUESKIN® SALT, FOILSKIN®, OR AIR-BLOC® LF

EXTEND FLASHING 76 mm RECOMMENDED (50 mm MIN) INTO ROUGH OPENING

76 mm MIN

AIR-BLOC® 16MR

JAMB

NOTES:

1. DETAIL SHOWS AIR-BLOC® 16MR ASSEMBLY INSTALLED OVER EXTERIOR GRADE GYPSUM SHEATHING. OTHER ACCEPTABLE SUBSTRATES INCLUDE PLYWOOD, OSB, CONCRETE, AND CONCRETE BLOCK.
2. INSULATION AND CLADDING NOT SHOWN FOR CLARITY.
3. INSTALL FLASHING AT SILL PAN EXTENDING 152 mm MINIMUM UP JAMB.
4. WINDOW INSTALLATION REQUIREMENTS TO BE VERIFIED BY DESIGN PROFESSIONAL.
5. REFER TO AIR-BLOC® 16MR GUIDE SPECIFICATION FOR RECOMMENDED INSTALLATION PROCEDURES.

Henry®

15 Wallsend Drive,
Scarborough, Ontario, M1E 3X6
800-486-1278 • www.henry.com

MANUFACTURER GUIDE DETAILS ARE FOR REFERENCE ONLY. HENRY® DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR DEVIATIONS IN DESIGN OR ENGINEERING. PROJECT SPECIFIC VERIFICATION IS RECOMMENDED PRIOR TO INSTALLATION.

AIR-BLOC® 16MR AIR AND VAPOUR BARRIER

REBATE WINDOW

METHOD B - AIR-BLOC® 16MR INSTALLED BEFORE SELF-ADHERED OR LIQUID APPLIED FLASHING

SCALE: N.T.S.

10-25-2016

AB16MR - 6A2