

**KOP-R-LASTIC® SEALANT**  
(TROWEL SEALANT UNTIL  
MEMBRANE EDGE IS FULLY  
COATED TO PROMOTE  
WATER SHEDDING)

EXTEND FLASHING  
76 mm MIN

**BLUESKIN® VP160**

**BLUESKIN® VP160,  
BLUESKIN® BUTYL  
FLASH, BLUESKIN® SA,  
BLUESKIN® SALT, OR  
FOILSKIN®**

**KOP-R-LASTIC® SEALANT**  
(TROWEL SEALANT UNTIL  
MEMBRANE EDGE IS FULLY  
COATED TO PROMOTE  
WATER SHEDDING)

LAP FLASHING 76 mm  
MIN ONTO EACH SIDE OF  
SUBSTRATE AT DISSIMILAR  
MATERIAL TRANSITIONS

50 mm OVERLAP WHERE  
**BLUESKIN® VP160** LAPS  
ONTO FLASHING

REFER TO HENRY®  
DETAIL BSVP160 - 8B OR  
BSVP160 - 8C SUBSTRATE  
GAPS FOR DEFLECTION  
JOINT RECOMMENDATIONS

**BLUESKIN® VP160,  
BLUESKIN® BUTYL  
FLASH, BLUESKIN® SA,  
BLUESKIN® SALT,  
OR FOILSKIN®**

CONTACT HENRY® FOR  
RECOMMENDATIONS  
WHERE THE ROOFING  
ASSEMBLY TRANSITIONS  
ONTO THE AIR BARRIER.

**BLUESKIN® BUTYL  
FLASH, BLUESKIN® SA,  
BLUESKIN® SALT, OR  
FOILSKIN®**

**BLUESKIN® BUTYL  
FLASH, BLUESKIN® SA,  
BLUESKIN® SALT, OR  
FOILSKIN®**

OPTIONAL HENRY®  
AIR/VAPOUR BARRIER

**KOP-R-LASTIC® SEALANT**  
(TROWEL SEALANT UNTIL  
MEMBRANE EDGE IS FULLY  
COATED TO PROMOTE  
WATER SHEDDING)

#### NOTES:

1. DETAIL SHOWS **BLUESKIN® VP160** ASSEMBLY INSTALLED OVER EXTERIOR GRADE GYPSUM SHEATHING. OTHER ACCEPTABLE SUBSTRATES INCLUDE PLYWOOD, OSB, CONCRETE, AND CONCRETE BLOCK.
2. THE **BLUESKIN® VP160** ASSEMBLY SHALL BE INSTALLED TO PROVIDE A CONTINUOUS BARRIER TO PREVENT AIR AND WATER INTRUSION.
3. REFER TO **BLUESKIN® VP160** INSTALLATION GUIDELINES FOR RECOMMENDED INSTALLATION PROCEDURES.

# Henry®

15 Wallsend Drive,  
Scarborough, Ontario, M1E 3X6  
800-486-1278 • www.henry.com

MANUFACTURER GUIDE DETAILS ARE FOR REFERENCE ONLY. HENRY® DOES NOT ASSUME RESPONSIBILITY FOR ERRORS OR DEVIATIONS IN DESIGN OR ENGINEERING. PROJECT SPECIFIC VERIFICATION IS RECOMMENDED PRIOR TO INSTALLATION.

## **BLUESKIN® VP160 SELF-ADHERED WATER RESISTIVE AIR BARRIER**

### **PARAPET TRANSITION**

ROOFING ASSEMBLY WRAPPING  
OVER TOP OF PARAPET

SCALE: N.T.S.

09-29-2016

**BSVP160 - 9B**