



Notes

1. This detail allows the opening to be completed before the stack is in place. The metal sleeve and the clearance necessary will depend on the temperature of the material handled by the stack.
2. Cant strips are not required when the cap flashing or all plies are thermofused.
3. Vertical wood member may be replaced by an upgraded assembly as shown in detail MB-13E97.

modifiedPLUS® Roofing Systems

STACK FLASHING

CONVENTIONAL ROOFING ASSEMBLY

Scale: N.T.S.

Plot: 1:5

Issued: 05-14-97

Revision: 05

MB-10E97



15 Walsend Drive, Toronto ON M1E 3X6
 Technical Services - 800-486-1278
 Email: techservices@henry.com
 www.ca.henry.com